

## **TREMstop MCR**

### **A Metal Restricting Collar**

#### **Product Description**

TREMstop MCR is a metal restricting collar for use with TREMstop WS to fabricate a firestop device in the field to fit a hub or uncommon pipe size.

#### **Basic Uses**

TREMstop MCR is used to direct the intumescent action of the TREMstop WS inward to close off any gaps or voids left when a combustible penetration burns away during a fire.

#### **Features and Benefits**

TREMstop MCR is zinc-coated to reduce sharp edges and is made of 28-gauge steel, permitting easy manipulation.

#### **Packaging**

1.4 in. x 25 ft (3.6 cm x 7.6 m)  
2.4 in. x 50 ft (6.1 cm x 15.2 m)

#### **Availability**

TREMstop MCR is immediately available from your local Tremco representative or distributor throughout the United States and Canada.

#### **Application/Installation**

TREMstop MCR is for use in conjunction with TREMstop WS in firestop systems. Wrap appropriate layers of TREMstop WS around pipe and secure temporarily with wire or foil tape. Cut the necessary length of TREMstop MCR to cover the TREMstop WS with a 2 inch overlap. Bend the tabs outward and slide assembly along penetrating item until it is flush with the building assembly. Mechanically fasten the TREMstop MCR with the number of fasteners detailed in the firestop system. Fasteners to be located symmetrically surrounding the device. As an alternate, use TREMstop D.

#### **Limitations**

- Not recommended for use with passive fire containment systems not listed or approved by Tremco.

#### **Warranty**

Tremco warrants its Firestop Materials to be free of defects, but makes no warranty as to appearance or color. Since methods of application and on-site conditions are beyond our control and can affect performance, Tremco makes no other warranty, expressed or implied, including warranties of MERCHANTABILITY and FITNESS FOR A PARTICULAR PURPOSE with respect to Firestop Materials. Tremco's sole obligation shall be, at its option, to replace or to refund the purchase price of the quantity of the Firestop Materials proved to be defective and Tremco shall not be liable for any loss or damage.

